STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121329
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 71877

1. OWNER Robert Silva
MAILING ADDRESS PO Box 1883 Winnemucca NV

ADDRESS AT WELL LOCATION 350 Silva Road
Winnemucca NV
Subdivision Name: County: Pershing

2. LOCATION SE¼NW¼ Sec25T34N/ R37E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 009-190-15 (Parcel. No.)

Latitude 40 47'34.94" UTM E ☐ NAD 27
Longitude 117 46'14.52" N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	10	10
Cobbles/gravel		10	30	20
Clay		30	35	5
Gravel		35	45	10
Clay		45	60	15
Course Sand	X	60	80	20
Clay		80	95	15
Sand/gravel	X	95	140	45

NAD27
40.793134°N
117.769757°W

2014 APR 10 PM 12:44
NV STATE ENGINEER'S OFFICE

Date started: March 31, 20 14
Date completed: April 1, 20 14

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15-20		4

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+18	140

Perforations:
Type of perforation Factory Cut
Size of perforation 3/32X4
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed By driller performing actual drilling on site or contractor
Date April 7, 2014

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com