STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121338
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69102

1. OWNER Karl Trimble & Melissa Trimble
MAILING ADDRESS 459 Del Mar Drive SE St. George, UT 84790

ADDRESS AT WELL LOCATION 4155 East Mallas Rd McGill, NV 89138
Subdivision Name: County: White Pine

2. LOCATION ¼ NE ¼ Sec 13 T 20 N/S R 64 E
PERMIT/WAIVER No. 010-020-12
Issued by Water Resources Parcel No.

Latitude 39.602438° Longitude -114.714074
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay, Gravel, Boulders		0	50	50
Solid Granite	X	50	300	250

NAD 27
39.602501°N
114.713222°W

RECEIVED 2014 DEC 1 PM 2:16 STATE ENGINEERS OFFICE

Date started: Nov. 4, 20 14
Date completed: Nov. 19, 20 14

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		8 Hours

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8	Inches	0 Feet	300 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625		.250	+2	300

Perforations:
Type of perforation Mill
Size of perforation 1/8 x 2 1/2 x 6

From 100	feet to 120	feet
From 140	feet to 160	feet
From 180	feet to 200	feet
From 240	feet to 260	feet
From 280	feet to 300	feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 100	☐ Pumped	☒ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No to ☐ Pumped ☒ Poured
Type: 1/2" Gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2458
Signed (By driller performing actual drilling on-site or contractor)
Date Nov. 24, 2014

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627