STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121350
Permit No. 70069
Basin 028

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72322

1. OWNER Tim Delong Family Trust
MAILING ADDRESS P.O. Box 367 Imlay NV.
ADDRESS AT WELL LOCATION Black Rock Desert Near 7 Troughs Lovelock NV
Subdivision Name: County: Pershing

2. LOCATION SW ¼ SW ¼ Sec 17 T 32 N/S R 30 E
PERMIT/WAIVER No. 70069 (Issued by Water Resources) 002-320-04 (Parcel No.)
Latitude N 40° 38.072 Longitude W 118° 38.493
UTM E ____ N ____ ■ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ■ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil	NO	0	2	2
Sand	NO	2	10	8
Gravel clay sand	NO	10	125	115
Clay Sand	NO	125	165	40
Clay sand gravel	yes	165	300	135

RECEIVED 2014 DEC -4 PM 12:03 STATE ENGINEERS OFFICE

NAD 27
40.634552°N
118.644434

Date started: 11-9, 20 14
Date completed: 11-14, 20 14

7. Water Level
Static water level: 145 feet below land surface
Artesian Flow: ____ G.P.M. ____ P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	NA	6

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 inches	0 Feet	300 Feet
inches	Feet	Feet
inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	Steel	.188	0	20
6 5/8	PVC	Sched 40	20	300

Perforations
Type of perforation Slot
Size of perforation .20
From 240 feet to 300 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 20 ☐ Pumped ■ Poured
☐ Cement Grout ____ to ____ ☐ Pumped ☐ Poured
☐ Concrete Grout ____ to ____ ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout ____ to ____ ☐ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 100 to 300 ☐ Pumped ■ Poured
Type: 3/8" pea
Bentonite Chips: ■ Yes ☐ No 20 to 100 ☐ Pumped ■ Poured
Type: 3/8" chip

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV.
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature] By driller performing actual drilling on-site or contractor
Date 11-20-14

(Rev. 05-03)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627