

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 121398  
Permit No. \_\_\_\_\_  
Basin No. \_\_\_\_\_

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37771  
WELL NAME (if applicable): MW-7

1. OWNER/CLIENT NAME Jose Rios / 7-Eleven  
MAILING ADDRESS PO Box 711  
Dallas TX 75221

DETAILED ADDRESS AT WELL LOCATION  
5110 S. Maryland Parkway  
Subdivision Name: \_\_\_\_\_ County: Clark

2. PLS LOCATION SW 1/4 NW 1/4 26 Sec 21S N/S 61 E  
PERMIT/WAIVER NO. 1162-26-210-03  
Issued by Water Resources Current Parcel No.

Latitude 36° 09' 09.06" N UTM E  NAD 27  
Longitude 115° 09' 16.91" W UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deeper: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt			0	
Base TYPE II				1
Sity Gravel			1	5
Gravelly Silt Dry			5	6
Caliche			6	14
Gravelly Silt Moist			14	18
Caliche			18	23
Sity with sand Wet			23	26

9. INSTRUCTION

Depth Drilled: 25 Feet Depth Cased: 25 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>10.25</u> Inches	<u>0</u> Feet <u>26</u> Feet
	Inches Feet Feet
	Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.500</u>	<u>2.01</u>	<u>0.237</u>	<u>0</u>	<u>25</u>

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout 0.05 to 6  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Bentonite Chips 5 to 8  Pumped  Poured

Gravel Pack [ > 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Sand Pack [ < 0.2 in. ] 8 to 26  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 23-Apr, 20 14  
Date completed: 23-Apr, 20 14

7. WATER QUALITIES  
Static water level: 16 Feet below land surface  
Artesian Flow: NA G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: NA ° Fahrenheit  
Water Quality: Clear

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

PERFORATIONS:

Type of perforation: Factory  
Size of perforation: 0.02

From 10 Feet To 25 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name National EWP Contractor  
Address 5241 Schrills St. Las Vegas NV 89118 Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 00735355  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2111-T1  
Signed: Bob ref  
By driller performing actual drilling on site or contractor  
Date: 5/7/2014

36,1525166  
-115,154672  
NAD 27