

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72382

1. OWNER Nevada Department of Wildlife ADDRESS AT WELL LOCATION HC 10 Box 10808
 MAILING ADDRESS 1100 Valley Road Ely, NV 89301
Reno, NV 89512

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T. 15 N. S. R. 64 E. White Pine County
 PERMIT NO. 84280T Issued by Water Resources Parcel No. 012-020-05 Subdivision Name 3C Ranch

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Quartzite boulders/sand		3	30	27
Quartzite boulders/sand/yl. shaly	V	30	40	10
Quartzite boulders/sand		40	60	20
Quartzite boulders/gravel/sand	V	60	80	20
Gravel/brown sand/brown clay		80	90	10
Brown clay/brown sand/gravel	V	90	110	20
Yellow clay/sandstone		110	120	10
Brown clay/sand/gravel		120	130	10
Gravel/sand/brown clay	V	130	140	10
Gravel/sand/brown clay	V	140	150	10
Pea gravel/sand/brown clay	V	150	160	10
Brown clay/sand		160	170	10
Pea Gravel/sand/brown clay	V	170	200	30
Coarse sand/brown clay		200	210	10
Brown clay/pea gravel/sand		210	300	90

Note: 12.6" to 12" gravel and sand water carrying strata from 210-300

8. WELL CONSTRUCTION
 Depth Drilled 300 Feet Depth Cased 300 Feet
 HOLE DIAMETER (BIT SIZE)
13.5 Inches From 0 Feet To 300 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
9.625	16.52	.188"	0	240
8.625	22.36	.250"	240	300

Perforations:
 Type perforation Factory Slots
 Size perforation .100"
 From 120 feet to 300 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 300 feet

9. WATER LEVEL
 Static water level 30 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 55 °F Quality 130 TDS 8.0 PH

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name David Gibson Contractor LLC Contractor
 Address P.O. Box 203 Contractor
Lund, NV 89317
 Nevada contractor's license number issued by the State Contractor's Board 0077987
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2315
 Signed David Gibson
 By driller performing actual drilling on site or contractor
 Date 12-16-2014

Date started 09/27 2014
 Date completed 10/6/2014

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80-100</u>	<u>170</u>	<u>8</u>

Plugged By Well LOG 125846

RECEIVED
 2014 DEC 17 AM 8:55
 STATE ENGINEERS OFFICE

NAD 27
 39.71243041
 114.80903562