STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121564
Permit No.
Basin No. 092A

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72208
WELL NAME (if applicable)

1. OWNER/CLIENT NAME Michael Barenbak
MAILING ADDRESS 1470 Doric Dr
Reno Nv 89503

DETAILED ADDRESS AT WELL LOCATION 1325 American Flat Rd
Reno Nv 89508
Subdivision Name: Red Rock Estates County: Washoe

2. PLS LOCATION SW ¼ SE ¼ 33 Sec 22 N/S 19 E
PERMIT/WAIVER NO. _____ (Issued by Water Resources) 079-420-16 (Current Parcel No.)

Latitude 39.72494 UTM E ☐ NAD 27
Longitude 119.85323 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand,brown clay, rock			0	20
tan clay,rock,sand			20	55
gravel,brown clay			55	90
black and white dig			110	165
fractured black and white dig			165	190
black and white dig			190	325
black and white dig and grey clay			325	395
grey and black fractured rock			395	460
TD 460				

NAD 27
39.725031°N
119.852203°W

Date started: 6-Nov, 20 14
Date completed: 11-Dec, 20 14

9. INSTRUCTION
Depth Drilled: 460 Feet Depth Cased: 460 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	50	Feet
8 1/2	Inches	50	Feet	395	Feet
6 1/8	Inches	395	Feet	460	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	395
5	9.25	.188	380	460

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☒ Concrete Grout	0	to	50	☐ Pumped	☒ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	395	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS

Type of perforation: Factory
Size of perforation: 3/32 x 3

From	Feet	To	Feet
355		395	
440		460	

7. WATER QUALITIES
Static water level: 300 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 68 ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		1 hr

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name A.S.A.P.Pump & Well Service,LLC. (Contractor)
Address P.O. Box 60130 Reno, Nevada 89506 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2362

Signed: Larry Welch (By driller performing actual drilling on site or contractor)
Date 12/11/2014

RECEIVED 2014 DEC 22 PM 1:35 STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.