

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121581
Permit No. _____
Basin 087

AS-4

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 70114

1. OWNER Testland Properties Corp 7-11 inc
MAILING ADDRESS PO box 711 Dallas tx 75221

ADDRESS AT WELL LOCATION 1680 S. Nevada Blvd Reno

2. LOCATION SE 1/4 SW 1/4 Sec 6 T 19 N R 20 E
PERMIT/WAIVER No. MO 1959 008-073-01
Issued by Water Resources Parcel No. _____

Subdivision Name: Truckee Meadows County: Washoe
Latitude 39.5449621 UTM E 7260899.0 NAD 27
Longitude -119.78248848 N 43860900.77 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
asphalt		0	6"	6"
Silt/sand w/gravel		6'	10'	4'
well graded gravel/sand		10'	20'	10'
poorly graded sand w/gravel		20'	30'	10'
well graded gravel		30'	40'	10'
gravel		40'	50'	10'
clayey sand, moist	X	50'	55'	5'
clayey sand, fine gravel		55'	60'	5'
NAD 27 39.545051°N 119.781465°W				

9. WELL CONSTRUCTION			
Depth Drilled	Feet	Depth Cased	Feet
<u>61</u>		<u>61</u>	

HOLE DIAMETER (BIT SIZE)			
Inches	From	To	Feet
<u>6 1/2</u>	<u>0</u>	<u>61</u>	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>Sch 40</u>	<u>0</u>	<u>61</u>

Perforations:
Type of perforation slotted
Size of perforation .010
From 61 feet to 55 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 51 to 1 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
 Gravel Pack: Yes No 61 to 53 Pumped Poured
 Type: 2/12
 Bentonite Chips: Yes No 53 to 51 Pumped Poured
 Type: medium

Date started: Nov 23, 2014
Date completed: Nov 24, 2014

7. Water Level
Static water level: 53.3 feet below land surface
Artesian Flow: N/A G.P.M. _____ P.S.I. _____
Water Temperature: N/A °F
Quality: _____

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cross Drilling & Testing Contractor
Address 950 Howard meridian Contractor
Nevada contractor's license number 38113
issued by the State Contractor's Board
Nevada driller's license number issued by the 2488
Division of Water Resources, the on-site driller
Signed _____
Date 12-17-14
By driller performing actual drilling on-site or contractor

RECEIVED
2014 DEC 22 PM 1:38
STATE ENGINEER OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)