

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 121585  
Permit No. \_\_\_\_\_  
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63297  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Inna Daley DETAILED ADDRESS AT WELL LOCATION 3760 Pershing Lane  
MAILING ADDRESS 3760 Pershing Way Washoe Valley, NV 89704  
NE SE Subdivision Name: \_\_\_\_\_ County: Washoe

2. PLS LOCATION S8 1/4 SW 1/4 Sec 16 N/S 20 E Latitude 39.27736 UTM E  NAD 27  
PERMIT/WAIVER NO. 650-484-05 Longitude 119.77394 UTM N  NAD 83/WGS 84  
Issued by Water Resources Current Parcel No.

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # 14645  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  Auger  Rotary  RVC  
 Mining / Dewater  Corn / Ind  Stock  Air  Mud  Sonic  
 Test / Other  Mun / QM  Rec  Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Sand			0	7	7
Clay			7	10	3
Large Sand			10	1	
9 Small Gravel			1	53	43
Dense Clay			53	72	19
Large sand			72	1	
8 Small Gravel			1	200	128

9. WELL CONSTRUCTION  
Depth Drilled: 200 Feet Depth Cased: 200 Feet  
HOLE DIAMETER (BIT SIZE)  
From 11 Inches To 200 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>0.188</u>	<u>12</u>	<u>20</u>
<u>6 5/8</u>		<u>SDR 21</u>	<u>20</u>	<u>200</u>

PERFORATIONS:  
Type of perforation: Factory cut  
Size of perforation: 3/32  
From 160 Feet To 200 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS

Sanitary Seal 0 to 56  Pumped  Poured  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 56  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] 56 to 200  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_  Pumped  Poured

Date started: 11-19-14, 20  
Date completed: 11-21-14, 20

7. WATER QUALITIES  
Static water level: 59' Feet below land surface  
Artesian Flow: 6.14 G.P.M. 30+ P.S.I.  
Water Temperature: Cold ° Fahrenheit  
Water Quality: Clear

8. WELL TEST DATA

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>120 FT</u>	<u>30+</u>		<u>3</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name BLAIN DRILLING & PUMP CO INC  
P.O. Box 1255  
Address Carson City, NV 89702  
Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 464984  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2311  
Signed: C. Robinson  
By driller performing actual drilling on site or contractor  
Date: 12-1-14

Replaces well log 14645