STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 121599
Permit No.
Basin No. 088

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72406
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Jon Norris
MAILING ADDRESS 365 Tucker Rd
Reno Nv 89521

DETAILED ADDRESS AT WELL LOCATION 365 Tucker Rd
Reno Nv 89521
Subdivision Name: Sky View Estates County: Washoe

2. PLS LOCATION SE ¼ SE ¼ 6 Sec 17 N/S 20 E
PERMIT/WAIVER NO. 045-561-01
Issued by Water Resources Current Parcel No.

Latitude 39.36304 UTM E ☐ NAD 27
Longitude 119.77328 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# 17083
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Fractured rock			280	320
Green volcanic rock			320	340
Red volcanic rock			340	345
TD 345				
Started Drilling at 280'				
was open borchole from 280-300'				
NAD27				
39.363129°N				
119.772261°W				

Date started 16-Dec , 20 14
Date completed 17-Dec , 20 14

7. WATER QUALITIES
Static water level: 195 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 90 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		1 hr

9. INSTRUCTION
Depth Drilled: 65 Feet Depth Cased: 345 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	280	Feet	345	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9.62	.188	245	345

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	In Place	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 3/32 x 3

From	Feet	To	Feet
305	Feet	345	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name A.S.A.P.Pump & Well Service,LLC.
Contractor
Address P.O. Box 60130 Reno, Nevada 89506
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 35387C
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2362
Signed: Larry Wells
by driller performing actual drilling on site or immediate
Date

2014 DEC 31 PM 12:00
RECEIVED
DIVISION OF WATER RESOURCES
STATE ENGINEER'S OFFICE

(Rev. 12-13)
USE ADDITIONAL SHEETS IF NECESSARY
pg. 1 of pg. 1

Deepens Well log 17083