

Well log # 121754



Stantec

Stantec Consulting Services Inc.
1165 East Jennings Way, Suite 101
Elko, NV 89801-7977
Tel: (775) 738-8766
Fax: (775) 738-2264

595 Double Eagle Court, Suite 2000
Reno, NV 89521-9005
Tel: (775) 747-5777
Fax: (775) 747-2177

**Valmy Power Plant
Summary Log of Replacement Monitoring Well**

MW-3RR: Completed 01/27/2015

Well Number	From	To	Interval	Lithology	Groundwater
MW-3RR	0	46	46	Sand with silt and clay	--
	46	50	4	Basalt	Water at 46 feet

Notes: All intervals in feet below ground surface.
Groundwater depth as first encountered in drilling.



Walter M. Martin
Martin, CPG-11358

2/11/15
Date

RECORDED
INDEXED
2015 FEB 19 10:11 AM
STATE ENGINEERS OF FLORIDA