

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 54/05

PRINT OR TYPE ONLY

1. OWNER Howe Trust ADDRESS AT WELL LOCATION 205 Nugget Lane
 MAILING ADDRESS Dayton NV

2. LOCATION SE 1/4 NW 1/4 Sec 16 T. 16 N/S R. 22 E 1400 County
 PERMIT NO. 019-442-04 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Dir. clay		0	9	
SAND clay		8	85	
gravel clay		85	114	
SAND clay	X	114	220	
Small gravel		220	300	

8. WELL CONSTRUCTION
 Diameter hole 10 5/8 inches Total depth 300 feet
 Casing record 6 5/8 1884411 SDR21 JJC
 Weight per foot 12.04 Thickness 188.50
 Diameter From To
6 5/8 inches 11 feet 20 feet
6 inches 20 feet 300 feet
 Surface seal: Yes No Type Concrete
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 300 feet
 Perforations:
 Type perforation CANDLER CUT
 Size perforation .015 X 4
 From 260 feet to 300 feet

Date started June 1 1905
 Date completed June 4 1905

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Analist</u>	<u>304</u>		<u>3 hrs</u>

9. WATER LEVEL
 Static water level 105 feet below land surface
 Flow NA G.P.M. P.S.I.
 Water temperature 80 ° F. Quality clear

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Blain Drilling Contractor
 Address PO 1255 COO NV Contractor
 Nevada contractor's license number 46497
 Nevada contractor's drillers number 2134
 Nevada driller's license number 2134 Actual Driller
 Signed [Signature] Contractor
 Date JUN 30 2005

BAILER TEST
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours