

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 122192  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

1. OWNER GREYSTONE NEVADA LLC ADDRESS AT WELL LOCATION HENDERSON  
MAILING ADDRESS 2490 PASEO VERDE PKWY  
#120 HENDERSON NV 89074 Subdivision Name: CADENCE NEIGHBORHOOD #2 - CLARK  
2. LOCATION NE 1/4 NE 1/4 Sec 05 T 22 N R 63 E Latitude 36.0691335 UTM E 840058.24  NAD 27  
PERMIT/WAIVER No. 179-05-510-001 Longitude 114.9610813 N 26227374.14  NAD 83/WGS 84  
Issued by Water Resources Parcel No. State Plane

NOTICE OF INTENT NO. 37229

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  Air  Other

5. WELL TYPE  
 Cable  Rotary  RVC  
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCK + GRAVEL		0	40	40
CLAY + GRAVEL		40	60	20
SANDY CLAY BROWN		60	110	50
CLAY + GRAVEL		110	135	25
SAND + GRAVEL	W.B.	135	140	5
CLAY + GRAVEL		140	150	10
SANDY CLAY BROWN		150	180	30
SILT + SAND	W.B.	180	188	8
CLAY + SAND BROWN		188	220	32
CALICHE + SAND	W.B.	220	230	10
CLAY + SAND		230	350	120
SAND + SILT	W.B.	350	375	14

9. WELL CONSTRUCTION  
Depth Drilled 375 Feet Depth Cased 374 Feet  
HOLE DIAMETER (BIT SIZE)  
9 7/8 Inches From SURFACE Feet 375 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.500	2.866	SCH 80 0.337	4+G.L.	374

Perforations:  
Type of perforation FACTORY SCREEN  
Size of perforation .010 INCH  
From 349 feet to 369 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 20% Bentonite Grout 25 FT. to SURFACE  Pumped  Poured  
Gravel Pack:  Yes  No 347 to 374  Pumped  Poured  
Type: SAND #1-20  
Bentonite Chips:  Yes  No 347 to 25  Pumped  Poured  
Type: BARIOD HOLE PLUG 3/8" INCH

8. WELL TEST DATA  
TEST METHOD:  Bailor  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)

7. Water Level  
Static water level: 121 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COOL °F  
Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name BUDGET DRILLING LLC. Contractor  
Address 1170 Darcy Ln. Primm NV 89060 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 0077029  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573  
Signed Donnie Brown By driller performing actual drilling on-site or contractor  
Date 3-26-2015