STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122371
Permit No.
Basin No. 089

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68185
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Joe & Lisa Kreskey
MAILING ADDRESS 3725 Pershing WV 89704
DETAILED ADDRESS AT WELL LOCATION 3725 Pershing Lane Washoe Valley, NV 89704
Subdivision Name: County: Washoe

2. PLS LOCATION NE ¼ SE ¼ 06 Sec 16 N/S 20 E
PERMIT/WAIVER NO. 1050.463.21
Issued by Water Resources Current Parcel No.
Latitude 39.27784 UTM E 39.27892 ☐ NAD 27
Longitude 119.77484 UTM N 119.7748 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
top Sand			0	3	3
Clay			3	15	12
Sand & Gravel			15	75	60
Clay			75	83	8
Sand & clay			83	90	7
Clay			90	99	9
Black Sand			99	117	18
Clay & Sand			117	132	15
Small Sand to			132	/	
Med. Gravel			/	143	11
Black & White			143	/	
Granite with			/	/	
Quartz			/	187	44
Nad 27					
39.27901 °N					
119.773783 °W					

Date started: 5-4-15, 20
Date completed: 5-6-15, 20

9. WELL CONSTRUCTION
Depth Drilled: 187 Feet Depth Cased: 187 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	145	Feet
	Inches		Feet		Feet
9 7/8	Inches	145	Feet	187	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	187

PERFORATIONS:
Type of perforation: Factory cut
Size of perforation: 1/16
From 127 Feet To 187 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS
☒ Sanitary Seal 0 to 60
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 60 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Bentonite Grout to ☐ Pumped ☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:
☒ Gravel Pack [> 0.2 in.] 60 to 187 ☐ Pumped ☒ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

7. WATER QUALITIES
Static water level: 86 Feet below land surface
Artesian Flow: N/A G.P.M. 50+ P.S.I.
Water Temperature: 64 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
120 ft	50+		2
replaces unknown log			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Blain Drilling
Contractor
Address PO 1255 CC NV 89702
Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 46498A
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2326
Signed: C. Robinson
By driller performing actual drilling on site or contractor
Date: 5-8-15

RECEIVED 2015 MAY 13 PM 3:16 STATE ENGINEER'S OFFICE

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY
(NSPO Rev 11-12)
(O) 627