STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122409
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72251

1. OWNER Ruben Garcia/Red Lion Chevron
MAILING ADDRESS 2065 Idaho St Elko, NV 89801
ADDRESS AT WELL LOCATION 2175 Idaho St Elko, NV 89801
Subdivision Name: County: ELKO

2. LOCATION SW ¼ NE ¼ Sec 11 T 34 (N)/S R 55 E
PERMIT/WAIVER No. M 101996 (Issued by Water Resources) 0015660013 (Parcel No.)
Latitude N 40.850169°
Longitude W 115.74570°
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☐ Other ☒ AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MW-7				
Silt Clay		0	20	20
Sand Silt Gravel		20	40	20
Silt Sand Clay	60	40	80	40
MW-7				
NAD 27				
40.850749°N				
115.744666°W				

Date started: 4/13/15 , 20 15
Date completed: 4/13/15 , 20 15

9. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		Schedule 40	0	80

Perforations:
Type of perforation Factory slot
Size of perforation .020
From 40 feet to 80 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 36 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 38 to 80 ☐ Pumped ☒ Poured
Type: Silica Sand 10/20
Bentonite Chips: ☒ Yes ☐ No 36 to 38 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Chips

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: < 55 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ-TECH DRILLING, INC. (Contractor)
Address PO BOX 940 (Contractor)
MERIDIAN, ID. 83680
Nevada contractor's license number issued by the State Contractor's Board 0038018
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 12 LTD
Signed (By driller performing actual drilling on site of contractor)
Date 5/4/15

RECEIVED 2015 MAY 11 AM 11:46 STATE ENGINEER'S OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY