STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122420
Permit No. 75775
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72995

1. OWNER Rick and Kim Perigo
MAILING ADDRESS 10335 Road 176
Terra Bella California 93270

ADDRESS AT WELL LOCATION Highway 6
White Pine County
Subdivision Name: County:

2. LOCATION NE ¼ NE ¼ Sec. 31 T 13 S R 61 E
PERMIT/WAIVER No. 75775 (Issued by Water Resources) 011-220-02 (Parcel No.)
Latitude N 38° 57' 03.5" Longitude W 115° 09' 16.8"
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☑ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill, Rocks + Dirt		0	16	16
Rock		16	19	3
Gravel + Rock	✓	19	21	2
Gravel, Rock + Sand	✓	21	34	13
Clay + Rocks		34	40	6
Clay + Rocks		40	49	9
Rock		49	55	6
Clay + Rock		55	57	2
Rock		57	70	13
Clay + Rock		70	76	6
Rock-Solid	✓	76	400	324

NAD 27
38.951032°N
115.153812°W

Date started: 3-20-2015, 20 15
Date completed: 4-25-2015, 20 15

7. Water Level
Static water level: 24 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 55 °F
Quality: 8.2 Ph 380 TDS

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air Lift	550		8

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
21.5	Inches	0	Feet	400	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4	33.41	1/4	0	18.5
12 3/4	49.61	3/4	18.5	20
14	19	3/4 SDR 17 pvc	20	400

Perforations:
Type of perforation Factory Saw
Size of perforation .032
From 120 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☑ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☑ Cement Grout 0 to 100 ☑ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☑ Yes ☐ No 100 to 400 ☐ Pumped ☑ Poured
Type: 3/8
Bentonite Chips: ☐ Yes ☑ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David Gibson Contractor (Contractor)
Address Lund, NV 89317 (Contractor)
0077887
Nevada contractor's license number issued by the State Contractor's Board 0077887
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2315
Signed Dennis A. Eldridge (By driller performing actual drilling on-site or contractor)
Date April 30, 2015

RECEIVED 2015 MAY 15 PM 3:00 ENGINEERS OFFICE

(Rev. 05-00)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627