STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122607
Permit No. 84861
Basin No. 105

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66077
WELL NAME (If applicable): Field 16

1. OWNER/CLIENT NAME Park Livestock
MAILING ADDRESS P.O. Box 53 Topaz CA 96133

DETAILED ADDRESS AT WELL LOCATION Buckeye Road
Subdivision Name: County: Douglas

2. PLS LOCATION SE ¼ NE ¼ 29 Sec 13 N/S 20 E
PERMIT/WAIVER NO. 84861-T (Issued by Water Resources) 84875-T (Current Parcel No.)

Latitude 38* 57.687 N UTM E ☐ NAD 27
Longitude 119* 45.285 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☒ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Surface Clay			0	12	12
Coarse Gravel			12	43	31
Blue Clay			43	46	3
Coarse Gravel			46	55	9
Gravel with Clay			55	71	16
Sand and Gravel			71	95	24
Gravel with Clay			95	140	45
Gravel			140	145	5
Gravel with Clay			145	175	30
Gravel			175	210	35
Gravel with Clay			210	240	30
Gravel			240	310	70
Gravel with Clay			310	340	30
NAD 27					
38.961543°N					
119.753739°W					

Date started: 16-May, 20 15
Date completed: 19-May, 20 15

9. WELL CONSTRUCTION
Depth Drilled: 340' Feet Depth Cased: 330' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
42"	Inches	0'	Feet	100'	Feet
24"	Inches	100'	Feet	340'	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
30"		.375"	0'	100'
16"		.312"	+2'	330'

PERFORATIONS:
Type of perforation: Johnson Stainless Steel Wire Wrap Screen
Size of perforation: 0.080"
From 160' Feet To 210' Feet
From 230' Feet To 320' Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal		to		
☐ Neat Cement		to	☐ Pumped	☐ Poured
☒ Cement Grout	0'	to 100'	☒ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Bentonite Grout		to	☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	0'	to 340'	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 23.4' Feet below land surface
Artesian Flow: No G.P.M. 0 P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: N/A

8. WELL TEST DATA
Test Method: ☐ Bailer ☒ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Constant	2,500	96.3'	12 Hours

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Stonehouse Drilling and Construction, LLC. (Contractor)
Address 7801 Lakeside Drive Reno, NV 89511 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0069994
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): # 1713

Signed: (By driller performing actual drilling on site or contractor)
Date: 06.10.15

RECEIVED JUN 10 2015 NEVADA DIVISION OF WATER RESOURCES

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY