STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122621
Permit No. 84198T
Basin No. 013

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72642
WELL NAME (if applicable): Lower Bally

1. OWNER/CLIENT NAME Coleman Valley Ranch
MAILING ADDRESS PO Box 60370
Reno NV 89506

DETAILED ADDRESS AT WELL LOCATION Barrel Springs Rd
Near Vya NV.
Subdivision Name: County: Washoe

2. PLS LOCATION SW ¼ SW ¼ 8 Sec 46 N/S 19 E
PERMIT/WAIVER NO. 061-171-16
Issued by Water Resources Current Parcel No.

Latitude N41*55'07.68 UTM E ☐ NAD 27
Longitude W119*55'15.000 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☒ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top soil		No	0	4
Hard red clay with shale layers		No	4.	100
Hard fractured basalt		Yes	100	220

NAD27
41.98908°N
119.886446°W

Date started: 5-May, 20 15
Date completed: 5/10 ~~10/05/15~~, 20 15

7. WATER QUALITIES
Static water level: 110 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 58 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
10	N/A	4

9. CONSTRUCTION
Depth Drilled: 220 Feet Depth Cased: 220 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8 3/4"	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	Sced 40	20	220
4"	Steel	.188	0	20

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	20	☐ Pumped	☒ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to	50	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	220	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From	Feet	To	Feet
180		220	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 76778
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 730

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 6-8-15

RECEIVED
2015 JUN 15 PM 12:39
STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.