STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122653
Permit No. 76736
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72857
WELL NAME *(if applicable)*:

1. OWNER/CLIENT NAME Richard Babbit
MAILING ADDRESS 3200 Dallas Drive
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 3200 Dallas Drive
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION SE ¼ NE ¼ 34 Sec 19 N/S 28 E
PERMIT/WAIVER NO. 76736 *Issued by Water Resources* 008-753-17 *Current Parcel No.*

Latitude 39.4707 UTM E ☐ NAD 27
Longitude 118.82324 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # Unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ ~~Domestic~~ ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☒ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	12
Brown Clay			12	14
Brown Sand			14	43
Gray Clay			43	46
Gray Sand			46	51
Black Clay			51	56
Gray Clay			56	58
Gray Sand			58	64
Brown Clay			64	78
Brown Gravel			78	88
Black Clay			88	93
Black Sand			93	109
Gray Clay			109	124
Gray Sand			124	168
Brown Clay		X	168	173
Brown Sand		X	173	179
NAD27				
39.470783°N				
118.922253°W				

Date started: 16-Feb , 20 15
Date completed: 17-Feb , 20 15

7. WATER QUALITIES
Static water level: 26 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		

9. INSTRUCTION
Depth Drilled: 179 Feet Depth Cased: 179 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	179	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4.1	.316	18	179

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	105	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	159	to	179	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.

From	174 Feet	To	179	Feet
From	Feet	To		Feet
From	Feet	To		Feet
From	Feet	To		Feet
From	Feet	To		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. *Contractor*
Address P.O. Box 1265 Fallon, NV 89406 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2307
Signed: *By driller performing actual drilling on site or contractor*
Date: 2/25/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown well log