STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122659
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72868
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Perez, Juan
MAILING ADDRESS 7770 Flying K Ranch
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 6033 Westwind Way
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NE ¼ SE ¼ 19 Sec 19 N/S 28 E
PERMIT/WAIVER NO. 008-152-46
Issued by Water Resources *Current Parcel No.*

Latitude 39.49389 UTM E ☐ NAD 27
Longitude -118.87616 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # Unknown
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	18
Brown Clay			18	23
Brown Sand			23	28
Brown Clay			28	34
Brown Sand			34	71
Black Clay			71	75
Black Sand			75	82
Gray Clay			82	86
Gray Sand			86	91
Brown Clay			91	118
Brown Sand			118	128
Gray Sand		X	128	140

NAD 27
39.493974°N
118.875171°W

Date started: 7-Feb , 20 15
Date completed: 7-Feb , 20 15

7. *WATER QUALITIES*
Static water level: 30 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. *CONSTRUCTION*
Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	18	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4.1	.316	18	140

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to	105	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	105	to	140	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.

From 135	Feet	To 140	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O. Box 1265 Fallon, NV 89406
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2307

Signed:
By driller performing actual drilling on site or contractor
Date: 2/10/2014

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown Well log