

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 122667
Permit No. _____
Basin 073A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72096

1. OWNER EDWARD + STACI BRISTOW ADDRESS AT WELL LOCATION 55 DESERT VIEW DR.
MAILING ADDRESS 125 SPRING DR. ROCKY CANYON SUB. LOVELOCK NV 89419
LOVELOCK, NV 89419 Subdivision Name: _____ County: PERSHING

2. LOCATION NW 1/4 NW 1/4 Sec 9 T 29 N/S R 33 E Latitude _____ UTM E 391060 NAD 27
PERMIT/WAIVER No. Dom 15-24 011-031-011 Longitude _____ N 4472519 NAD 83/WGS 84
issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Topsoil</u>	-	<u>0'</u>	<u>10'</u>	<u>10</u>
<u>Sand - dirt</u>	-	<u>10'</u>	<u>40'</u>	<u>30</u>
<u>Sand - mixed clay</u>	-	<u>40'</u>	<u>80'</u>	<u>40</u>
<u>Gravel - rock</u>	<u>Yes</u>	<u>80'</u>	<u>100'</u>	<u>20</u>
<u>Hard rock - mixed Gravel</u>	<u>Yes</u>	<u>100'</u>	<u>130'</u>	<u>30</u>
<u>Gravel - mixed sand</u>	<u>Yes</u>	<u>130'</u>	<u>150'</u>	<u>20</u>
<u>Gravel - mixed clay</u>	<u>Yes</u>	<u>150'</u>	<u>160'</u>	<u>10</u>

9. WELL CONSTRUCTION

Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>10-5/8</u>	<u>0'</u>	<u>160'</u>	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6-5/8"</u>		<u>.188</u>	<u>+1'</u>	<u>160'</u>

Perforations:

Type of perforation slotted - cut

Size of perforation 1/4" wide 5" long

From	feet to	feet
<u>120'</u>	<u>140'</u>	feet
<u>140'</u>	<u>160'</u>	feet
		feet
		feet
		feet

Annular Seal: Yes No

Material	to	Pumped	Poured
<input type="checkbox"/> Neat Cement		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Concrete Grout	<u>5'</u> to <u>30'</u>	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured
<input type="checkbox"/> 20% Bentonite Grout		<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured

Gravel Pack: Yes No 100" to 160" Pumped Poured

Type: 3/8"

Bentonite Chips: Yes No 35' to 110' Pumped Poured

Type: 3" chips

Date started: 6-10, 2015
Date completed: 6-16, 2015

7. Water Level

Static water level: 80' feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 52 °F
Quality: GOOD

8. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80+</u>	<u>Unk.</u>	<u>3</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LBJ DRILLING & PUMP COMPANY, INC. Contractor
Address P.O. BOX 902 - Winnemucca, NV 89446 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0009605A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807

Signed Joe Boggio By driller performing actual drilling on site or contractor Joe Boggio
Date 7-07-2015