STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123038
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37876
WELL NAME (*If applicable*): MW-4

1. OWNER/CLIENT NAME: Stewart Environmental
MAILING ADDRESS: 9101 West Sahara Ave. #15-503.1
Las Vegas, NV, 89117

DETAILED ADDRESS AT WELL LOCATION: 3435 S. Jones Blvd
Las Vegas , NV
Subdivision Name: County: Clark

2. PLS LOCATION: NE ¼ NE ¼ 14 Sec 21 N/(S) 60 E
PERMIT/WAIVER NO.: MO-3081 (Issued by Water Resources) 163-14-502-010 (Current Parcel No.)

Latitude: 36*07'35.97"N UTM E:
Longitude: 115*13'31.77"W UTM N:
☑ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Asphalt over gravelly sand			0	3"
Silty sand with some gravel				
clayey sand			3"	23
Sandy claywith some gravel			23	28
Clayey sand with some gravel			28	30
Gravelly sand			30	32
Sandy clay with trace gravel			32	98
Very moist to wet at 90				

DCNR/DWR/SNBC RECEIVED AUG 05 2015

Date started: 24-Jul, 20 15
Date completed: 24-Jul, 20 15

9. INSTRUCTION
Depth Drilled: 98 Feet Depth Cased: 98 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	98	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	4.5	0.154	0	98

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☑ Neat Cement	2	to	74	☑ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	74	to	76	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	76	to	98	☐ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
78		98	

7. WATER QUALITIES
Static water level: 83 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name (Contractor): National EWP
Address (Contractor): 5241 Schirlls St Las Vegas NV 89118
Nevada contractor's license number as issued by the *State Contractor's Board*: 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller)*: 2512-ltd
Signed: Bob M (By driller performing actual drilling on site or contractor)
Date: 8-5-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1266583
-115.2254916 7

NAD 27