STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123074
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 38020
WELL NAME (If applicable): well#17

1. OWNER/CLIENT NAME: Clark County - Public Right of Way
MAILING ADDRESS: 500 South Grand Central PKWY 2nd floor Las Vegas NV 84155

DETAILED ADDRESS AT WELL LOCATION: Patrick LN. just East of McLeod Dr.,Clark County, NV.
Subdivision Name: County:

2. PLS LOCATION: SW ¼ NE ¼ 36 Sec 21S N/S 61 E
PERMIT/WAIVER NO.: DW -1390 (Issued by Water Resources) 161-36-699-027 (Current Parcel No.)

Latitude: 36 04' 44.73"N UTM E: ☐ NAD 27
Longitude: 115 06 24.17""W UTM N: x NAD 83/WGS 84

3. WORKED PERFORMED
x New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
x Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
x Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Strata	From	To
Packed Silt-silty clay			0	4
silty clay-calicchi			4	10
calicchi -red silty clay			10	11
Red silty clay - red silty clay			11	16
red silty clay-calicchi			16	24
calicchi - red silty clay			24	27
red silty clay-calicchi			27	32
calicchi -red clay			32	35
red clay			35	40
Note - Annular Material				
Gravel pack			0	10

DCNR/DWR/SNRO
RECEIVED
AUG 03 2015

Date started: 1-Jul , 20 15
Date completed: 1-Jul , 20 15

9. CONSTRUCTION
Depth Drilled: 40 Feet Depth Cased: 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	6	SCH 40	0	40

ANNULAR MATERIALS
Sanitary Seal x Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
Bentonite Chips	10	to 12	☐ Pumped	x Poured
x Gravel Pack [> 0.2 in.]	12	to 40	☐ Pumped	x Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: machine slot
Size of perforation: 0.032

From	Feet	To	Feet
20	Feet	40	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 16 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: Viking Drillers, Inc (Contractor)
Address: 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0034680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2361
Signed: Matthew J Payne (By driller performing actual drilling on site or contractor)
Date: 7/29/15

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.0791182
-115.1058839
NAD 27