STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123115
Permit No.
Basin No. 165

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74269
WELL NAME (If applicable): well#3

1. OWNER/CLIENT NAME BIA - Washoe Tribe of NV & CA
MAILING ADDRESS 311 E.Washington St. Carson City NV 89701

DETAILED ADDRESS AT WELL LOCATION 919 N HWY 395
, Douglas County NV
Subdivision Name: County:

2. PLS LOCATION SE ¼ SW ¼ 11 Sec 12N N/S 20 E
PERMIT/WAIVER NO. DW-117 (Issued by Water Resources) 1220110002009 (Current Parcel No.)

Latitude 38.911956' N UTM E ☐ NAD 27
Longitude 119.708935' W UTM N x NAD 83/WGS 84

3. WORKED PERFORMED
x New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
x Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
x Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
silty sand , cobble-silty clay			0	3
silty clay-silty sand cobble			3	6
silty sand cobble-clay			6	19
clay-silty cobble			19	21
silty cobble-clay			21	28
clay-silty cobble			28	30
Annular Materials				
0-10' - Steel Spacer				
~~10-15' Bentonite Seal~~				
NAD 27				
38.912049				
119.707927				

Date started: 3-Aug , 20 15
Date completed: 3-Aug , 20 15

7. WATER QUALITIES
Static water level: 9ft Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 30 Feet Depth Cased: 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	12	5/8	0	30

ANNULAR MATERIALS
Sanitary Seal x Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
Bentonite Chips	8 to	10	☐ Pumped	Poured
x Gravel Pack [> 0.2 in.]	10 to	30	☐ Pumped	x Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

3/8 pea gravel

PERFORATIONS:
Type of perforation: machine slot
Size of perforation: 0.032
From 10 Feet To 30 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Viking Drillers, Inc (Contractor)
Address 5950 Granite Lake Drive, Granite Bay, CA 95746 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0084680
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2361
Signed: Matthew J. [illegible] (By driller performing actual drilling on site or contractor)
Date: 8/13/2015

RECEIVED 2015 AUG 19 AM 11:26 STATE ENGINEERS OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY

Pg 1 of pg.