STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123267
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37796
WELL NAME (If applicable): PC-158

1. OWNER/CLIENT NAME: Nevada Environmental Response Trust
MAILING ADDRESS: 35 E Wacker DR. # 1550
Chicago Il 60601-2314

DETAILED ADDRESS AT WELL LOCATION: 325-399 E. Sunset Rd
Henderson, NV
Subdivision Name: County: Clark

2. PLS LOCATION: SE ¼ SW ¼ 36 Sec 21 N/S 62 E
PERMIT/WAIVER NO. (Issued by Water Resources): 161-36-801-004 (Current Parcel No.)

Latitude: 38* 4" 17.01" N UTM E: ☒ NAD 27
Longitude: 115* 0' 10.26" W UTM N: ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☒ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand			0	4
Silty Sand			4	12
Sand			12	15
Silty Sand			15	20
Silt			20	23

DCNR/DWR/SNBO
RECEIVED
APR 16 2015

Date started: 6-Nov, 20/4 15
Date completed: 6-Nov, 20/4 15

7. WATER QUALITIES
Static water level: 15 Feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: NA ° Fahrenheit
Water Quality: NA

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 23 Feet Depth Cased: 23 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 7/8"	Inches	0	Feet	23	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.68	0.154	0	23

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	0	to 5	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	5	to 7	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to	☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	7	to 23	☐ Pumped	☒ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: 0.02

From	Feet	To	Feet
8	Feet	23	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name: National EWP (Contractor)
Address: 5241 Schirlls St. Las Vegas, NV 89118 (Contractor)

Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2512-LTD

Signed: Bob M (By driller performing actual drilling on site or contractor)
Date: 2/9/2015

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.0773916 NAD
-115.00285 27