STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123293
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34612
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME MM HOLDINGS, LLC
MAILING ADDRESS 2941 LORELIE
PAHRUMP, NV 89048

DETAILED ADDRESS AT WELL LOCATION 2340 S. RED ROCK DR.
PAHRUMP, NV 89048
Subdivision Name: CV UT:8-B BLK:8 LOT:24 *County:* NYE

2. PLS LOCATION SW ¼ NE ¼ 29 Sec 20-S N/S 53 E
PERMIT/WAIVER NO. 039-022-34
Issued by Water Resources *Current Parcel No.*

Latitude N36° 11.117' UTM E 2572' ☐ NAD 27
Longitude W116° 02.280 UTM N 14' ☐ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
SURFACE			0	4
GRAY CLAY & CALICHE			4	18
LIMESTONE			18	27
GRAY CLAY & CALICHE			27	52
BROWN CLAY			52	102
BROWN CLAY & CALICHE		X	102	175
LIMESTONE		X	175	187
BROWN CLAY			187	191
BROWN CLAY & CALICHE		X	191	200

DCNR/DWR/SNDC
RECEIVED
AUG 10 2015

Date started: 21-Jul , 20 15
Date completed: 23-Jul , 20 15

9. CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	3.92	.28	0	200

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
■ Concrete Grout	0	to 50	☐ Pumped	■ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☐ Gravel Pack [> 0.2 in.]	50	to 200	☐ Pumped	■ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: SAW CUT
Size of perforation: 1/4" WIDTH 3" LONG
From 160 Feet To 200 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

7. WATER QUALITIES
Static water level: 74 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC
Contractor
Address P O BOX 56 PAHRUMP, NV 89041
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 17563A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1324

Signed: Jim Pike
By driller performing actual drilling on site or contractor
Date: 07/28/15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.1853583
-116.0371232
NAD 27