STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123304
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36777

1. OWNER Jerry S. Johnston
MAILING ADDRESS P.O. Box 281
Alamo Nv. 89001

ADDRESS AT WELL LOCATION 1695 S. Richardville, rd.
Alamo, Nv. 89001
Subdivision Name: County: Lincoln

2. LOCATION NE ¼ NW ¼ Sec 32 T 6 N OR 61 E
PERMIT/WAIVER No. 011-200-33
Issued by Water Resources Parcel No.

Latitude 37° 23' 17.27" UTM E
Longitude 115° 09' 53.97" N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ PVC
☐ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Snd. w/cobbles		0	40	40
Snd. w/gravel layers	✓	40	105	65
gravel w/cly. layers		105	140	35
cly.		140	170	30
cly. w/ limestone layer		170	177	7

DCNR/DWR/SNBO
RECEIVED
JUN 11 2015

Date started: 5/5, 20 15
Date completed: 5/15, 20 15

7. Water Level
Static water level: 30 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 177 Feet Depth Cased 177 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 1/2	Inches	0	Feet	177	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	PVC	SDR-21	0	177
Surface Protective Casing:				
8	steel	.188		7

Perforations:
Type of perforation Machined
Size of perforation 4R .032 Screen
From 77 feet to 137 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☒ Neat Cement 0 to 55 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 55 to 177 ☐ Pumped ☒ Poured
Type: 3/8"
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budget Drilling LLC
Contractor
Address Darcy Ln.
Contractor
Pahrump, Nv. 89060
Nevada contractor's license number 77029
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2160
Signed
By driller performing actual drilling on-site or contractor
Date 6/9/15

(Rev. 05-08)
USE ADDITIONAL SHEETS IF NECESSARY

37.3881694
-115.1641411
NAD 27

(NSPO 3-08) (O) 627