STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123345
Permit No.
Basin No. 045

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73753
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME WANDA PERRY
MAILING ADDRESS 442 LIPPARELLI LN #12
SPRING CREEK, NV 89815

DETAILED ADDRESS AT WELL LOCATION 308 LAZY T LN
Subdivision Name: PLEASANT VALLEY *County:* ELKO

2. PLS LOCATION NW ¼ NE ¼ 26 Sec 33N N/S 57 E
PERMIT/WAIVER NO. 023-018-004
Issued by Water Resources *Current Parcel No.*

Latitude UTM E 625234 ☒ NAD 27
Longitude UTM N 4508433 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
TOP SOIL & GRAVEL			0	5
GRAVEL			5	140
TAN CLAY & GRAVEL			140	160
GRAVEL		X	160	220

NAD 27
40.719203
115.517258

Date started: 1-Sep , 20 15
Date completed: 2-Sep , 20 15

9. CONSTRUCTION
Depth Drilled: 220 Feet Depth Cased: 218 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	220	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	218

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☒ Neat Cement	5	to 25	☐ Pumped	☒ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☐ Concrete Grout		to	☐ Pumped	☐ Poured
☒ Bentonite Chips	25	to 55	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	55	to 218	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: PLASMA CUT
Size of perforation: 3/16" X 4" 7 ROWS

From	Feet	To	Feet
178		218	

7. *WATER QUALITIES*
Static water level: 134 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 55 ° Fahrenheit
Water Quality: GOOD

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
AT 218'	40		1 HOUR
AT 180'	35		1/2 HOUR
AT 160'	17		10 MIN
AT 140'	2		10 MIN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name HACKWORTH DRILLING INC. *Contractor*
Address P.O. BOX 850, ELKO, NV 89803 *Contractor*
Nevada contractor's license number as issued by the *State Contractor's Board:* 026582
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1166
Signed: Dale C. Veden *By driller performing actual drilling on site or contractor*
Date: 9/4/2015

RECEIVED 2015 SEP 14 PM 12:
STATE ENGINEER'S OFFICE

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.