

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 123393  
Permit No. \_\_\_\_\_  
Basin No. \_\_\_\_\_

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37448  
WELL NAME (if applicable): L

1. OWNER/CLIENT NAME Clark County Water Reclamation  
MAILING ADDRESS 5857 E. Flamingo Rd LV NV 89122

DETAILED ADDRESS AT WELL LOCATION Broadbent & Tropicana

2. PLS LOCATION NE 1/4 NE 1/4 27 Sec 21 N 62 E  
PERMIT/WAIVER NO. DW1392 161-27-599-0  
Issued by Water Resources Current Parcel No.

Subdivision Name: \_\_\_\_\_ County: Clark  
Latitude 36° 5' 98.90" N UTM E  NAD 27  
Longitude 115° 15' 4.12" W UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Dewater  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
<u>sand drift &amp; clay</u>			<u>0</u>	<u>10</u>
<u>1/2" fine sand</u>			<u>10</u>	<u>18</u>
<u>clay sand &amp; gravel</u>				
<u>streaks</u>			<u>18</u>	<u>40</u>
<u>sandy clay &amp; boulders</u>			<u>40</u>	<u>50</u>
<u>Water Level 15'</u>				

9. INSTRUCTION

Depth Drilled: 50 Feet Depth Cased: 50 Feet

HOLE DIAMETER (BIT SIZE)

From	To	#
<u>24</u> Inches	<u>0</u> Feet	<u>50</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12 3/4</u>		<u>1/4</u>	<u>50</u>	<u>+1 1/2</u>

ANNULAR MATERIALS

Sanitary Seal  Yes  No

Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Bentonite Chips 11 Ft to 8 Ft  Pumped  Poured

Gravel Pack [ > 0.2 in. ] SUR to 50 Ft  Pumped  Poured

Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

PERFORATIONS:

Type of perforation: Torch Cut

Size of perforation: 1/8" x 4"

From 15 Feet To 50 Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

Date started: Aug 20 20 15  
Date completed: Aug 21 20 15

7. WATER QUALITIES

Static water level: \_\_\_\_\_ Feet below land surface

Artesian Flow: NO G.P.M. \_\_\_\_\_ P.S.I.

Water Temperature: COLD ° Fahrenheit

Water Quality: UNKNOWN

8. WELL TEST DATA

Test Method:	Bailer	X Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)	
<u>Pump</u>	<u>15</u>		<u>1</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.

Name Rain 2 Day, Inc. Contractor

Address 4740 Industry Park Court LV NV 89115 Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0078225

Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2325

Signed: [Signature]  
\*By driller performing actual drilling on site or contractor

Date: 25-Aug-15