STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 12517
Permit No.
Basin No. 179

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. ~~38200~~ 68209
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Charles Coleman
MAILING ADDRESS P.O. Box 663 McGill, NV 89318

DETAILED ADDRESS AT WELL LOCATION 2809 North 35th West St.
Subdivision Name: Cross Timbers *County:* White Pine

2. PLS LOCATION NE ¼ SW ¼ 15 Sec 17 N/S 63 E
PERMIT/WAIVER NO. 57
Issued by Water Resources *Current Parcel No.*

Latitude N39° 20.179' UTM E ☐ NAD 27
Longitude W114° 52.443' UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	3
Sand & Gravel			3	20
Clay, Sand Gravel			20	25
Sand, Gravel some Clay			25	40
Clay			40	45
Sand, Gravel with Clay				
Stringers			45	75
Clay and Sand			75	85
Course Sand		X	85	95
Mostly Brown Clay			95	115
Clay and small gravel			115	140
Clay and Sand			140	160
Course Sand and Gravel		X	160	173
Clay & Small Gravel			173	185
Clay			185	200
NAD27				
39.326317°N				
114.874050°W				

Date started: 19-Aug , 20 15
Date completed: 22-Aug , 20 15

7. *WATER QUALITIES*
Static water level: 83' Feet below land surface
Artesian Flow: NA G.P.M. NA P.S.I.
Water Temperature: Cold ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
Air Lift	150+	127	4 Hours

9. CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

		From		To	
12	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	20
6.625	4.95	SDR17	20	200

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
☒ Concrete Grout	-4	to 54	☐ Pumped	☒ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	54	to 200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Slotted
Size of perforation: 0.032

From	Feet	To	Feet
60	Feet	100	Feet
140	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Christiansen Drilling Inc (Contractor)
Address 557 Ely Avenue Ely, NV 89301 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 14796
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 968
Signed: *By driller performing actual drilling on site or contractor*
Date: 8/24/2015

RECEIVED 2015 SEP 3 PM 3:03 STATE ENGINEER'S OFFICE

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.