STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123568
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73952

1. OWNER Kevin Hancock
MAILING ADDRESS 5555 Weaver Road
NE Fallon, Nevada 89406

ADDRESS AT WELL LOCATION 5555 Weaver Road
Fallon, Nevada 89406
Subdivision Name: County: Churchill

2. LOCATION NW ¼ SE ¼ Sec 19 T 18 N/S R 29 E/W Latitude 347452 UTM E 0347459 ☒ NAD 27
PERMIT/WAIVER No. SW 006-831-02 Longitude N 4363294 ☐ NAD 83/WGS 84
Issued by Water Resources Parcel No

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sands		0	35	35
Brown clay		35	50	15
Black sands/clay	x	50	90	40
Grey sands/clay	x	90	115	25
Brown sands/gravel	x	115	147	32
Brown clay		147	148	1

NAD 27
39.407557
118.771801

Date started 10/02 , 20 15
Date completed 10/03 , 20 15

7. Water Level
Static water level 28 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		2

9. WELL CONSTRUCTION
Depth Drilled 148 Feet Depth Cased 148 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10-3/4	Inches	0	Feet	103	Feet
6-1/8	Inches	103	Feet	148	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.9	.188	+1	148

Perforations
Type of perforation Factory cut
Size of perforation .060
From 141 feet to 146 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 103 ☒ Pumped ☐ Poured
☐ Cement Grout to Pumped Poured
☐ Concrete Grout to Pumped Poured
☐ ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: ☐ Yes ☒ No to Pumped Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to Pumped Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corporation
Contractor
Address P.O. Box 888
Contractor
Fallon, Nevada 89407
Nevada contractor's license number issued by the State Contractor's Board 001175
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed
By driller performing actual drilling on-site or contractor
Date Oct 7-15

RECEIVED 2015 OCT -9 AM 11:43 STATE ENGINEER'S OFFICE

USE ADDITIONAL SHEETS IF NECESSARY

Rev. 05-08

(NSPO 3-08)

Replaces Unknown log

(O) 627