STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123579
Permit No.
Basin No. 069

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74208
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Matthias Zapatka
MAILING ADDRESS 514 American Way #5322
Box Elder SD 57719

DETAILED ADDRESS AT WELL LOCATION Pole Line Rd
Winnemucca NV 89445
Subdivision Name: Paradise valley Estates *County:* Humboldt

2. PLS LOCATION SE ¼ SW ¼ 33 Sec 40 N/S 39 E
PERMIT/WAIVER NO. *Issued by Water Resources* 4039-33-300-014 *Current Parcel No.*

Latitude N41*17'51.497 UTM E ☐ NAD 27
Longitude W117*35'30.881 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	6
Caliche		No	6	12
Gravel clay sand		No	12	55
Gravel clay sand		Yes	55	140

NAD 27
41.297738
117.590951

Date started: 8-Oct , 20 15
Date completed: 10/12/15 , 20 15

7. WATER QUALITIES
Static water level: ~~26~~ 21 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 61 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
35	N/A	~~4005-33-300-014~~ 4

9. CONSTRUCTION
Depth Drilled: 140 Feet Depth Cased: 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	140

ANNULAR MATERIALS

Sanitary Seal X ☒ Yes ☐ No

☒ Neat Cement	0	to	50	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	140	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From	Feet	To	Feet
100	Feet	140	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc. *Contractor*
Address 5140 Jungo Rd Winnemucca NV *Contractor*

Nevada contractor's license number as issued by the *State Contractor's Board:* 76778
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1563
Signed: *By driller performing actual drilling on site or contractor*
Date: ~~10~~ 11-4-15

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** pg. of pg.