STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123580
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74209
WELL NAME (If applicable):

1. OWNER/CLIENT NAME Mike James
MAILING ADDRESS PO Box 1572
WINNEMUCCA nv 89446

DETAILED ADDRESS AT WELL LOCATION 5845 Pelican Ln
Winnemucca NV 89445
Subdivision Name: JB Estates County: Humboldt

2. PLS LOCATION SW ¼ SE SE ¼ 2 Sec 35 N/S 37 E
PERMIT/WAIVER NO. 3537-02-476-001
Issued by Water Resources Current Parcel No.

Latitude N40*55'54.785 UTM E ☐ NAD 27
Longitude W117*46'48.929 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Sand		No	0	10
Sand clay		No	10	22
Gravel clay sand		No	22	100
Gravel clay sand		Yes	100	200

RECEIVED NOV 6 2015 STATE ENGINEER'S OFFICE

NAD 27
40.931981
117.779294

Date started: 14-Oct ,20 15
Date completed: 10/20/15 ,20 15

9. CONSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8"	Steel	.188	0	20
6 5/8"	PVC	Sched 40	20	200

ANNULAR MATERIALS
Sanitary Seal x ☒ Yes ☐ No

☒ Neat Cement	0	to	20	☒ Pumped	☐ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	20	to	50	☐ Pumped	☒ Poured
☒ Gravel Pack [> 0.2 in.]	50	to	200	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2

From	Feet	To	Feet
160	Feet	200	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

7. WATER QUALITIES
Static water level: 101 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30	N/A	8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 76778
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1563
Signed:
By driller performing actual drilling on site or contractor
Date: 11-4-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.