STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123586
Permit No. 82133
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 7353[redacted]
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Steve Venturacci
MAILING ADDRESS 8475 Allen Rd
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION Allen Rd
Fallon, NV
Subdivision Name: *County:* Churchill

2. PLS LOCATION NE ¼ SE ¼ 1 Sec 17 N/S 28 E
PERMIT/WAIVER NO. 82133
Issued by Water Resources *Current Parcel No.*

Latitude 39.36565 UTM E ☐ NAD 27
Longitude -118.786281 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☒ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Top Soil			0	25
Brown Clay			4	49
Green Clay			22	55
Black Clay			58	60
Black Gravel			107	125
Gray Gravel/Clay			125	135
Green Clay			135	161
Black Clay			161	218
Black Sand			218	225
Green Sand			225	237
Green Clay			237	242
Black Sand		X	242	260
Black Clay			260	300
NAD 27				
39.365731				
118.785297				

Date started: 21-Jul , 20 15
Date completed: 7-Oct , 20 15

9. CONSTRUCTION
Depth Drilled: 300 Feet Depth Cased: 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.96	.188	+2	300

ANNULAR MATERIALS

Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	100	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☐ Bentonite Chips		to		☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	100	to	300	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:

Type of perforation: Mill Cut
Size of perforation: 1/8.

From	240	Feet	To 260	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet
From		Feet	To	Feet

7. *WATER QUALITIES*
Static water level: Feet below land surface
Artesian Flow: 1 G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
40		1 Hour

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc. Contractor
Address P.O Box 1265 Fallon, NV 89407 Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2509
Signed: *By driller performing the well drilling on site or contractor*
Date: 10/14/2015

RECEIVED 2015 NOV -9 PM 2:21 STATE ENGINEERS OFFICE

(Rev 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.