STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123597
Permit No.
Basin No. 059

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63281
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Greg Woods
MAILING ADDRESS 3928 Churchill Dr
Lov NV 89704

DETAILED ADDRESS AT WELL LOCATION 3920 Churchill
Subdivision Name: County: Douglas

2. PLS LOCATION SE¼ SE ¼ 06 Sec 6 N/S 20 E
PERMIT/WAIVER NO. 088.4[illegible]-05
Issued by Water Resources *Current Parcel No.*

Latitude 39°27.67'N UTM E ☐ NAD 27
Longitude 119.7685 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☒ Replacement: Original well log # 82378
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thickness
Dirt			0	18	18
Brown Clay			18	51	33
Sands + Gravels			51	160	109
sum clay					
Salt + Pepper Granite			160	180	20
NAD 27					
39.276838					
119.769833					

Date started: 10-8, 20 15
Date completed: 10-9, 20 15

9. WELL CONSTRUCTION
Depth Drilled: 180 Feet Depth Cased: 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	75	Feet
9 7/8	Inches	75	Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+2	20
6 5/8		SDR 21	20	177

PERFORATIONS:
Type of perforation: Factory Cut
Size of perforation: 3/32
From 180 Feet To 140 Feet
From 120 Feet To 100 Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	0 to 56			
☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 56		☒ Pumped	☒ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ Bentonite Chips	to		☐ Pumped	☐ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	180 to 56		☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 80 Feet below land surface
Artesian Flow: No G.P.M. 30 P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
30		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Address P.O. Box 1255 Carson City, NV 89702
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 46498A
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2514

Signed: Bob Gallina
By driller performing actual drilling on site or contractor
Date: 10-21-15

(Rev. 08-12)
(NSPO Rev 11-12)

USE ADDITIONAL SHEETS IF NECESSARY

Replacing well log 82378

(O) 627