

RECEIVED

NOV 04 2015

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 123730
Permit No. 84784
Basin No. 138

STATE ENGINEER'S OFFICE
ELKO OFFICE
PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72740
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Nevada Board of Regents
MAILING ADDRESS

DETAILED ADDRESS AT WELL LOCATION Gund Ranch Grass Valley

2. PLS LOCATION NW 1/4 NE 1/4 8 Sec 23 N/S 48 E
PERMIT/WAIVER NO. 84784
Issued by Water Resources Current Parcel No.

Subdivision Name: County: Lander
Latitude 39 52'45.36 UTM E
Longitude 116 35'44.40 UTM N

3. WORKED PERFORMED
New Well [ ] Deepen: Orig WL#
Replacement: Original well log #
Recondition: Original well log #

4. PROPOSED USE
Domestic [ ] Irrigation [ ] Monitor [ ]
Mining / Dewater [ ] Com / Ind [ ] Stock [ ]
Test / Other [ ] Mun / QM [ ] Rec [ ]

5. WELL TYPE
Auger [ ] Rotary [x] RVC [ ]
Air [ ] Mud [x] Sonic [ ]
Other [ ]

LITHOLOGIC LOG table with columns: Material Encountered, Lost Circ., Water Strata, From, To. Includes entries for Top Soil, Sand/Gravel, Large Gravel, Sand / 3/8 Gravel, Gravel Large W/ fine sand.

INSTRUCTION table with columns: Depth Drilled, Hole Diameter (Bit Size) From, To. Includes handwritten entry: 100 Feet, 10 5/8" Inches, 0 Feet, 100 Feet.

CASING SCHEDULE table with columns: Size O.D. (Inches), Weight/Ft. (Pounds), Wall Thickness (Inches), From (Feet), To (Feet). Includes entries for 6 5/8, 6/5/8, SDR 17, 100, 20, 20, +1.5.

NAD 27
39.879344
116.594754

ANNULAR MATERIALS
Sanitary Seal [x] Yes [ ] No
Neat Cement 20 to Surface [ ] Pumped [x] Poured
Concrete Grout to [ ] Pumped [ ] Poured
Bentonite Chips 50 to 20 [ ] Pumped [x] Poured
Gravel Pack [> 0.2 in.] 100 to 50 [ ] Pumped [ ] Poured
Sand Pack [< 0.2 in.] to [ ] Pumped [ ] Poured

PERFORATIONS:
Type of perforation: manufactured
Size of perforation: 0.32
From 80 Feet To 100 Feet

Date started: 28-Sep, 20 15
Date completed: 30-Sep, 20 15

7. WATER QUALITIES
Static water level: 19 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool ° Fahrenheit
Water Quality: good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Reese Johnson Contractor
Address 197 Western Hills #7 Spring Creek Nv 89815 Contractor
Nevada contractor's license number as issued by the State Contractor's Board: 073955
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2421
Signed: [Signature]
Date: 10/16/2015

8. WELL TEST DATA table with columns: Test Method, G.P.M., Draw Down (Feet Below Static), Recorded Time (Hours). Includes entry for Air lift, 50, 40, 2.