STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124084
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37901
WELL NAME *(If applicable)*: HMW-23

1. OWNER/CLIENT NAME Nevasa Ready Mix Corp.
MAILING ADDRESS 2346 Dolphin court, Henderson,NV 89047

DETAILED ADDRESS AT WELL LOCATION 601 W. Bonanza Road
Las Vegas,NV
Subdivision Name: *County:* Clark

2. PLS LOCATION SW ¼ SW ¼ 27 Sec 20 N/S 61 E
PERMIT/WAIVER NO. MO-3095 *Issued by Water Resources* 139-27-401-001 *Current Parcel No.*

Latitude 36.17698"N UTM E
Longitude 115.15056"W UTM N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☒ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☒ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Clayey silt, Silty clay			0	3
Silty Clay/Gravel/dense thin			3	15
Caliche			15	18
Sandy clay/gravel			18	20
Caliche			20	27

Date started: 6-Oct, 20 15
Date completed: 6-Oct, 20 15

9. CONSTRUCTION
Depth Drilled: 27 Feet Depth Cased: 27 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	27	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.01	0.237	0	7

ANNULAR MATERIALS
Sanitary Seal ☒ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☒ Cement Grout	0	to	3	☒ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	3	to	5	☐ Pumped	☒ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☒ Sand Pack [< 0.2 in.]	5	to	27	☐ Pumped	☒ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..020

From 7	Feet	To 27	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

7. WATER QUALITIES
Static water level: 17 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 4221 W. Oquendo Rd. Las Vegas,NV 89118
Contractor

Nevada contractor's license number as issued by the *State Contractor's Board:* 0075355
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2526

Signed:
By driller performing actual drilling on site or contractor
Date: 10/14/2015

(Rev. 12-13) **USE ADDITIONAL SHEETS IF NECESSARY** **pg. of pg.**