STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124118
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37312

1. OWNER Trish Ripple
MAILING ADDRESS PO BOX 3360
Tonopah NV 89049-3360

ADDRESS AT WELL LOCATION 4821 E MARTIN AVE
PAHRUMP
Subdivision Name: FOX HOLLOW County: NYE

2. LOCATION SE ¼ NE ¼ Sec 29 T 21S N/S R 54 E
PERMIT/WAIVER No. 45-401-24
Issued by Water Resources Parcel No.

Latitude N36°05'44.3" UTM E ☐ NAD 27
Longitude W115°55'32.6" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
EXISTING 8"		0	240	-240
CLAY & CAILCHE		240	285	-45
CALICHE	WB	285	290	-5
CLAY & CALICHE		290	340	-50

Existing well log # 62501

Date started: 27-Aug, 20 15
Date completed: 28-Aug, 20 15

9. WELL CONSTRUCTION
Depth Drilled 340 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
EXISTING	Inches	0	Feet	240	Feet
7-7/8	Inches	240	Feet	340	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.94	.188	0	240
4.5	2.37	.248	0	340

Perforations:
Type of perforation FACTORY
Size of perforation .032
From 240 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

EXISTING Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 3 to 340 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 40 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2160
Signed (By driller performing actual drilling on site or contractor)
Date ~~9/16~~ 8/31/2015

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

36.0956745
-115.9248676
NAD 27