STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124122
Permit No. 85382T
Basin No. 187

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73629
WELL NAME (If applicable): LCW00006

1. OWNER/CLIENT NAME Elko Land and Livestock Co-Newmont
MAILING ADDRESS 1655 Mountain City Hwy.
Elko, NV. 89801

DETAILED ADDRESS AT WELL LOCATION 2.5 Miles South of Oasis, NV
Subdivision Name: County: Elko

2. PLS LOCATION NW ¼ NW ¼ 22 Sec 36 (N)S 66 E
PERMIT/WAIVER NO. 85382T (Issued by Water Resources) Current Parcel No.

Latitude 40.993633 UTM E [X] NAD 27
Longitude 114.505635 UTM N [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Deepen: Orig WL#
[ ] Replacement: Original well log #
[ ] Recondition: Original well log #

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Monitor
[ ] Mining / Dewater [ ] Com / Ind [ ] Stock
[X] Test / Other [ ] Mun / QM [ ] Rec

5. WELL TYPE
[ ] Auger [ ] Rotary [ ] RVC
[ ] Air [ ] Mud [ ] Sonic
[X] Other Flooded Rev.

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Alluvial			0	515
Limestone			515	1010
Dolomite			1010	1240
Limestone			1240	1775

NAD27
40.993633
114.505635

Date started: 9-Oct , 20 15
Date completed: 18-Nov , 20 15

7. WATER QUALITIES
Static water level: N/A Feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: 78 ° Fahrenheit
Water Quality: Good

8. WELL TEST DATA
Test Method: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
613		4

9. CONSTRUCTION
Depth Drilled: Feet 1775 Depth Cased: 1772 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
48	Inches	0	Feet	75	Feet
38	Inches	75	Feet	195	Feet
31	Inches	195	Feet	1775	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
40	210.93	.500	0	75
34	178.89	.500	0	195
24	99.61	.375	+2	1772

ANNULAR MATERIALS
Sanitary Seal X Yes [ ] No

[X] Neat Cement	50	to	446	[X] Pumped	[ ] Poured
[ ] Cement Grout		to		[ ] Pumped	[ ] Poured
[ ] Concrete Grout		to		[ ] Pumped	[ ] Poured
[X] Bentonite Chips	446	to	493	[X] Pumped	[ ] Poured
[X] Gravel Pack [> 0.2 in.]	493	to	1775	[ ] Pumped	X Poured
[ ] Sand Pack [< 0.2 in.]		to		[ ] Pumped	[ ] Poured
[ ] Other, explain:		to		[ ] Pumped	[ ] Poured

Sanitary Seal 0 to 50

PERFORATIONS:
Type of perforation: Louver
Size of perforation: 0.125

From	Feet	To	Feet
528	Feet	1772	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Boart Longyear (Contractor)
Address 2745 California Ave., SLC., UT. 84104 (Contractor)
Nevada contractor's license number as issued by the State Contractor's Board: 0021976
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1995
Signed: (By driller performing actual drilling on site or contractor)
Date: 19-Nov-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1