STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124127
Permit No.
Basin No. 10

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74290
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME David Lancett
MAILING ADDRESS 3000 Soda Lake Rd
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 3000 Soda Lake Rd
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION NW ¼ NW ¼ 16 Sec 19 N/S 28 E
PERMIT/WAIVER NO. 008-121-73
Issued by Water Resources *Current Parcel No.*

Latitude 39.51805 UTM E ☐ NAD 27
Longitude -118.856 UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log # unknown
☒ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Brown Sand			0	25
Brown Clay			25	28
Brown Sand			28	34
Brown Clay			34	36
Green Silt/Clay			36	41
Brown Sand		X	41	59
Gray Clay			59	60

NAD27
39.518134°N
118.855011°W

Date started: 18-Nov 20 15
Date completed: 18-Nov 20 15

7. WATER QUALITIES
Static water level: 37 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		1 hour

9. CONSTRUCTION
Depth Drilled: 60 Feet Depth Cased: 60 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	60	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	18
6	4	.312	18	60

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☐ No

☒ Neat Cement	0 to 55	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ Bentonite Chips	to	☐ Pumped	☐ Poured
☒ Gravel Pack [> 0.2 in.]	55 to 60	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]	to	☐ Pumped	☐ Poured
☐ Other, explain:	to	☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 1/8.
From 57 Feet To 60 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc.
Contractor
Address P.O Box 1265 Fallon, NV 89406
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 28064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 1753
Signed: Wayne Parsons
By driller performing actual drilling on site or contractor
Date: 11/19/2015

RECEIVED NOV 12 2015 DIVISION OF WATER RESOURCES

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Replaces Unknown Well log