

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 124129  
Permit No. \_\_\_\_\_  
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73540  
WELL NAME (if applicable): \_\_\_\_\_

1. OWNER/CLIENT NAME Charles Mifsud  
MAILING ADDRESS 3044 Bottom Rd  
Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION 3475 Alcorn Rd  
Fallon, NV 89406  
Subdivision Name: \_\_\_\_\_ County: Churchill

2. PLS LOCATION NW ¼ NE ¼ 34 Sec 19 N/S 28 E  
PERMIT/WAIVER NO. Dom 15-53 008-752-05  
Issued by Water Resources Current Parcel No.

Latitude 39.47398 UTM E  NAD 27  
Longitude -118.82858 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # 10810  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

LITHOLOGIC LOG				
Material Encountered	Lost Circ.	Water Strata	From	To
Fine Sand			0	8
Brown Sand			8	12
Brown Clay			12	18
Brown Sand			18	42
Gray Sand			42	51
Fine Gray Sand			51	60
Gray Sand			60	65
Brown Sand			65	73
Gray Sand			73	98
Brown Clay			98	119
Gray Clay			119	130
Gray Sand			130	133
Clay/Sand			133	150
Gray Sand			150	157
Green Sand			157	177
Brown Sand		X	177	185

9. INSTRUCTION  
Depth Drilled: 185 Feet Depth Cased: 185 Feet

HOLE DIAMETER (BIT SIZE)				
From		To		
<u>12</u> Inches	<u>0</u> Feet	<u>185</u> Feet		

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>20</u>
<u>6</u>	<u>4</u>	<u>.312</u>	<u>20</u>	<u>185</u>

ANNULAR MATERIALS  
Sanitary Seal  Yes  No  
 Neat Cement 5 to 105  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack [ > 0.2 in. ] 105 to 185  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 23-Oct , 20 15  
Date completed: 27-Oct , 20 15

7. WATER QUALITIES  
Static water level: 18 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ ° Fahrenheit  
Water Quality: \_\_\_\_\_

8. WELL TEST DATA			
Test Method:	Bailer	Pump	Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

PERFORATIONS:  
Type of perforation: Saw Cut  
Size of perforation: 1/8  
From 182 Feet To 185 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Parsons Drilling, Inc. Contractor  
Address P.O. Box 1265 Fallon, NV 89406 Contractor  
Nevada contractor's license number as issued by the State Contractor's Board: 29064  
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2509  
Signed: [Signature]  
Date: 10/30/2015

RECEIVED  
NOV 10 2 09 PM '15  
FALLON NV

(Rev 12-13)

USE ADDITIONAL SHEETS IF NECESSARY

Replaces well log 10810