

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68404

1. OWNER Charles & Laurie Brown ADDRESS AT WELL LOCATION 300 W Wagon Wheel White River Rd
 MAILING ADDRESS HL 34 Box 34167 W 9584 White River Rd
ELY, NV 89301 N 38° 54.737' W 115° 04.502'
 2. LOCATION NW 1/4 SW 1/4 Sec. 12 T. 12 N/S R. 61 E White Pine County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 011-480-02 Subdivision Name none

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	1.5	
lime stone gravel cobbles		1.5	10	
gravel cobbles clay conglomerate		10	123	
clay		123	128	
gravel	water	128	129	1
clay gravel cobbles		129	141	
gravel	water	141	143	2
clay gravel cobbles		143	160	
gravel	water	160	164	4
clay gravel cobbles		164	175	
gravel	water	175	176	1
clay gravel		176	187	
gravel	water	187	188	1
clay gravel		188	190	

8. WELL CONSTRUCTION
 Depth Drilled 190 Feet Depth Cased 190 Feet
 HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	0	160		
<u>6</u>	160	190		

 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>-18"</u>	<u>190</u>

 Perforations:
 Type perforation mill
 Size perforation 8 x 2.5" x 6 row
 From _____ feet to _____ feet
 From 130 feet to 190 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 5 feet to 55 feet

Date started Feb 12, 2014
 Date completed April 25, 2014

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>33</u>	<u>1</u>	<u>1 hr</u>

9. WATER LEVEL
 Static water level 128 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Maynard Well Drilling Contractor
 Address P.O. Box 64 Lund NV 89317 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 047226
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
 Signed Owner Maynard
 By driller performing actual drilling on site or contractor
 Date May 7-14