STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
GEW 3

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

OFFICE USE ONLY
Log No. 124170
Permit No. 84987 E
Basin 090

NOTICE OF INTENT NO. 71246

1. OWNER VILLAGE SPRINGS, LLC
MAILING ADDRESS 774 MAYS BLVD
INCLINE VILLAGE NV

ADDRESS AT WELL LOCATION 560 LAKESHORE BLVD
INCLINE VILLAGE, NV
Subdivision Name: County: WASHOE

2. LOCATION NE ¼ SE ¼ Sec 17 T 16 N/S R 18 E
PERMIT/WAIVER No. 84987 E (Issued by Water Resources) 122-128-07 (Parcel No.)
Latitude 39.249664 Longitude 119.980569
UTM E N ☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other SONIC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SEE ATTACHED				
LITH LOG				
NAD 27				
39.249757°N				
119.979546°W				

Date started: 6-13, 20 15
Date completed: 6-16, 20 15

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 147 @ 45° Feet Depth Cased 147 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10"	Inches	0	Feet	147	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		SCH 40 PVC	0	147

Perforations:
Type of perforation FACTORY SLOT PRE-PACKED
Size of perforation .020
From 147 feet to 102 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 98 to 0 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 147 to 100 ☐ Pumped ☒ Poured
Type: #3
Bentonite Chips: ☒ Yes ☐ No 100 to 98 ☐ Pumped ☒ Poured
Type: T-30 PELLETS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CASCADE DRILLING (Contractor)
Address 3000 DULUTH ST (Contractor)
WEST SACRAMENTO, CA
Nevada contractor's license number issued by the State Contractor's Board 73966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 3437
Signed (By driller performing actual drilling on-site or contractor)
Date 6-16-15

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627