STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124209
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 73239

1. OWNER David Fisk
MAILING ADDRESS 4800 Alcorn Road
Fallon, Nevada 89406

ADDRESS AT WELL LOCATION 4800 Alcorn Road
Fallon, Nevada 89406
Subdivision Name: County Churchill

2. LOCATION SW¼ SW ¼ Sec 28 T 19 N/S R 28 E
PERMIT/WAIVER No. 008-511-64
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 0340666 ☒ NAD 27
N 4370904 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	1
Brown sands		1	40	39
Brown clay		40	42	2
Brown sands	x	42	75	33
Clay		75	79	4
Black sand		79	135	56
Clay		135	138	3
Brown sand/gravel	x	138	155	17
Brown clay		155	157	2

NAD 27
39.474867
118.852396

Date started: 06/12, 20 15
Date completed: 06/12, 20 15

7. Water Level
Static water level: 23 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 57 °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		1 hour

9. WELL CONSTRUCTION
Depth Drilled 0-157 Feet Depth Cased 0-157 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	103	Feet	157	Feet
10-3/4	Inches	0	Feet	103	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-3/8	12.9	.188	0	157

Perforations:
Type of perforation Factory
Size of perforation .060
From 150 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement 3 to 103 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corporation
Contractor
Address P.O. Box 888
Contractor
Fallon, Nevada 89407
Nevada contractor's license number issued by the State Contractor's Board 0011752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed
By driller performing actual drilling on-site or contractor
Date June 30, 2015

RECEIVED
2015 JUL -6 PM 1:21
STATE ENGINEER'S OFFICE

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

Replacing unknown well log

(O) 627