STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124223
Permit No.
Basin No. 070

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 74220
WELL NAME (if applicable):

1. OWNER/CLIENT NAME Breanne Bealer
MAILING ADDRESS 4050 Piper DR
Winnemucca NV 89445

DETAILED ADDRESS AT WELL LOCATION 4050 Piper Dr
Winnemucca NV 89445
Subdivision Name: Airport Estates County: Humboldt

2. PLS LOCATION SE ¼ NE ¼ 23 Sec 35 N/S 37 E
PERMIT/WAIVER NO. 3537-23-200-029
Issued by Water Resources Current Parcel No.

Latitude N40°53'41.906 UTM E ☐ NAD 27
Longitude W117°46'35.103 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Deepen: Orig WL# ?
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Existing well		No	0	100
Grey clay,sand fine gravel		Yes	100	200

RECEIVED
2016 FEB -1 PM 1:36
STATE ENGINEERS OFFICE

NAD 27
40.895070
117.775454

Date started: 24-Nov, 20 15
Date completed: 11/30/15, 20 15

7. WATER QUALITIES
Static water level: 92 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15	N/A	6

9. INSTRUCTION
Depth Drilled: 200 Feet Depth Cased: 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8"	Inches	100	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	Pvc	Sched 40	90	200

ANNULAR MATERIALS
Sanitary Seal ☐ Yes ☒ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout NA to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ Bentonite Chips to ☐ Pumped ☐ Poured
☐ Gravel Pack [> 0.2 in.] to ☐ Pumped ☐ Poured
☐ Sand Pack [< 0.2 in.] to ☐ Pumped ☐ Poured
☐ Other, explain: to ☐ Pumped ☐ Poured

PERFORATIONS:
Type of perforation: slot
Size of perforation: 0.2
From 120 Feet To 200 Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet
From Feet To Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Allied Drilling Inc.
Contractor
Address 5140 Jungo Rd Winnemucca NV
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 76778
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1563
Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 12-14-15

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

Deepening unknown well log