STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124228
Permit No. 85463T
Basin 207

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72852

1. OWNER NDOW
MAILING ADDRESS 4600 Kietzke Lane Suite D-135 Reno Nev 89502
ADDRESS AT WELL LOCATION Mile Marker #1850 SR 318 Sunnyside Nev
Subdivision Name: 0 County: NYE

2. LOCATION SW ¼ NW ¼ Sec 33 T 7 N/S R 62 E
PERMIT/WAIVER No. 85463T NA
Issued by Water Resources Parcel No.
Latitude N 38°42247 UTM E ☐ NAD 27
Longitude W 115°02218 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Boulders	X	0	85	85
Boulders Clay-gravel	X	85	185	100
Hard Clay		185	200	15

NAD27
38.422519°N
115.021334°W

Date started: Dec , 20 15
Date completed: Dec , 20 15

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
13 1/2	Inches	0 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	200

Perforations:
Type of perforation factory
Size of perforation 1/8" X 6"
From 105 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 100 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 102 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 100 to 102 ☐ Pumped ☒ Poured
Type: bentonite pellets

7. Water Level
Static water level: 19 feet below land surface
Artesian Flow: 0 G.P.M. 0 P.S.I.
Water Temperature: Cool °F
Quality: fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	170'	6

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps
Contractor
Address HC61 Box 54 Hiko NV 89017
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0028266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 7191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 12-9-2015

(Rev. 06-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(O) 627