STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124277
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete and return to Division of Water Resources in accordance with NRS and NAC 534.340

NOTICE OF INTENT NO 73946

1. OWNER Colby Frey
MAILING ADDRESS 1045 Dodge Lane
NW Fallon, Nevada 89406

ADDRESS OF WELL LOCATION 1045 Dodge Lane
Fallon, Nevada 89406
Subdivision No. Lot County: Churchill

2. LOCATION se nw Sec 5 T 17 N R 29 E
PERMIT/WAIVER No 006-091-70
Latitude Longitude
UTM E 0348575 N 4359087 ☒ NAD 27 ☐ NAD 83/WGS 84
Project No

3. WORKED PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands		0	20	20
Brown Silt	x	20	48	28
Green Clay		48	60	12
Black sands/clay	x	60	140	80

NAD 27
39.369864
118.757812

Date Started 12/08 20 15
Date Completed 12/11 20 15

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14-3/4	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10-3/4		1/4	+1	140

Perforations
Type of perforation Factory cut
Size of perforation .090 Two (2) inch cut
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
x ☐ Neat Cement 3 to 103 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 130 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 103 to 130 ☐ Pumped ☒ Poured
Type:

7. Water Level
Static water level 23' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: not tested

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200		4

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corporation
Contractor
Address P.O. Box 888
Contractor
Fallon, Nevada 89407
Nevada contractor's license number issued by the State Contractor's Board 0011752
Nevada driller's license number issued by the Division of Water Resources, the 772
Signature
By driller performing actual drilling on-site or contractor
Date Dec-2-15

USE ADDITIONAL SHEETS IF NECESSARY

(Rev 6-06)
(NSPO 3-08)
(O) 627

Replacing unknown well log