STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124404
Permit No
Basin No. 092 B

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 72033
WELL NAME (if applicable)

1. OWNER/CLIENT NAME William Bates
MAILING ADDRESS 5735 Sun Valley Blvd
Sun Valley, NV 89433

DETAILED ADDRESS AT WELL LOCATION
3508 Indian Ln Reno, NV 89506
Subdivision Name County Washoe

2. PLS LOCATION NE ¼ SE ¼ 11 SEC 20 T 19 R
PERMIT/WAIVER NO 552-060-10
Issued by Water Resources Former Permit No

Latitude 39.61445 UTM E ☐ NAD 27
Longitude -119.81046 UTM N ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition. Original well log #

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ■ Rotary ☐ RVC
■ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Test Calc	Water Strata	From	To
Sand			0	10
Sand & Rock			10	20
Sand, Rock, and Brown Clay			20	240
TD 240				
NAD 27				
39.614540				
119.809435				

RECEIVED 2016 FEB 16 PM 12:
STATE ENGINEERS OFFICE

Date started 2-Feb , 20 16
Date completed 8-Feb , 20 16

7. WATER QUALITIES
Static water level 50 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 ° Fahrenheit
Water Quality: Clear

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M	Draw Down (Feet Below Static)	Recorded Time (Hours)
20+		0.5

9. INSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	58	Feet
8 1/2	Inches	58	Feet	198	Feet
6 1/4	Inches	198	Feet	240	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	0.188	+2	198
5 9/16	10 79	0.188	180	240

ANNULAR MATERIALS
Sanitary Seal ■ Yes ☐ No

☐ Neat Cement		to	☐ Pumped	☐ Poured
☐ Cement Grout		to	☐ Pumped	☐ Poured
■ Concrete Grout	0	to 58	☐ Pumped	■ Poured
☐ Bentonite Chips		to	☐ Pumped	☐ Poured
■ Gravel Pack [> 0.2 in.]	58	to 200	☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]		to	☐ Pumped	☐ Poured
☐ Other, explain:		to	☐ Pumped	☐ Poured

PERFORATIONS
Type of perforation Factory Sawed
Size of perforation: 3/32 x 3

From 178	Feet	To 198	Feet
From 220	Feet	To 240	Feet
From	Feet	To	Feet
From	Feet	To	Feet
From	Feet	To	Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name A.S.A.P.Pump & Well Service,LLC.
Contractor
Address P.O. Box 60130 Reno, Nevada 89506
Contractor

Nevada contractor's license number as issued by the State Contractor's Board 35387C
Nevada well driller's license number as issued by the Nevada Division of Water Resources 2362

Signature Larry Welch
Date 2/8/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. 1 of pg. 1