STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124439
Permit No.
Basin No.

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37917
WELL NAME (If applicable): HM-64

1. OWNER/CLIENT NAME Jason Reed/ NV Energy
MAILING ADDRESS 6226 W. Sahara Ave. MS30
Las Vegas, NV 89146

DETAILED ADDRESS AT WELL LOCATION 501 Wally Kay Way
Moapa, NV 89025
Subdivision Name: County: Clark

2. PLS LOCATION NE ¼ SW ¼ 5 Sec 15 N S 66 E
PERMIT/WAIVER NO. MO-3126 042-05-301.005
Issued by Water Resources Current Parcel No.

Latitude 36*39'26.53"N UTM E ☑ NAD 27
Longitude 114*37'56.54"W UTM N ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☑ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☑ Auger ☐ Rotary ☐ RVC
☐ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To
Air knifed			0	8
Sandy silt moist, fine gravel			8	20
medium sand, wet, trace silt			20	25
Fine sand, wet, clay wet fine sand			25	31

DCNR/DWR/SNBC
RECEIVED
FEB 09 2016

Date started: 11-Jan , 20 16
Date completed: 11-Jan , 20 16

7. WATER QUALITIES
Static water level: Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)

9. INSTRUCTION
Depth Drilled: 31 Feet Depth Cased: 31 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	31	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.01	0.237	0	30

ANNULAR MATERIALS
Sanitary Seal ☑ Yes ☐ No

☐ Neat Cement		to		☐ Pumped	☐ Poured
☑ Cement Grout	0	to	6	☑ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☑ Bentonite Chips	6	to	8	☐ Pumped	☑ Poured
☐ Gravel Pack [> 0.2 in.]		to		☐ Pumped	☐ Poured
☑ Sand Pack [< 0.2 in.]	8	to	31	☑ Pumped	☑ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

PERFORATIONS:
Type of perforation: Factory
Size of perforation: ..020

From		To	
10	Feet	30	Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet
	Feet		Feet

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name National EWP
Contractor
Address 4221 W. Oquendo Rd. Las Vegas, NV 89118
Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526

Signed: [signature]
By driller performing actual drilling on site or contractor
Date: 1/15/2016

(Rev. 12-13) USE ADDITIONAL SHEETS IF NECESSARY pg. of pg.

36.6573694 NAD
-114.632372 29