

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT**

OFFICE USE ONLY
Log No. 124632
Permit No. _____
Basin No. _____

**PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 37934
WELL NAME (if applicable): MW-20

1. OWNER/CLIENT NAME CV Propco LLC
MAILING ADDRESS 1505 South Pavilion Center DR.
Las Vegas, NV 89135

DETAILED ADDRESS AT WELL LOCATION 4425 Aldebaran Ave
Las Vegas, NV
Subdivision Name _____ County: Clark

2. PLS LOCATION SE 1/4 NW 1/4 20 Sec 21 N/S 61 E
PERMIT/WAIVER NO. NO-34110-3113 162-20-214-001
Issued by Water Resources Current Parcel No.

Latitude 36.10942*N UTM E NAD 27
Longitude 115*18333*W UTM N NAD 83/WGS 84

3. **WORKED PERFORMED**
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # _____
 Recondition: Original well log # _____

4. **PROPOSED USE**
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. **WELL TYPE**
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. **LITHOLOGIC LOG**

Material Encountered	Lost Circ.	Water Strata	From	To
Fill			0	1
Clayey Silt w/ gravel			1	3
Silty Sand w/ gravel			3	7
Clayey sand			7	9
Caliche			9	11
Sandy Clay			11	12
Caliche		<u>12.5</u>	12	14
Sandy clay			14	17
Clayey sand w/ gravel			17	21
Sandy Clay			21	24
Clayey Sand			24	26

9. **INSTRUCTION**

Depth Drilled: 26 Feet Depth Cased: 26 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10.25</u>	<u>0</u>		<u>26</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>2.01</u>	<u>0.237</u>	<u>0</u>	<u>25.5</u>

Date started: 2-Feb 20 16
Date completed: 2-Feb 20 16

ANNULAR MATERIALS

Sanitary Seal Yes No

<input type="checkbox"/> Neat Cement _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Bentonite Chips <u>0</u> to <u>8</u>	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Gravel Pack [> 0.2 in.] _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
<input checked="" type="checkbox"/> Sand Pack [< 0.2 in.] <u>8</u> to <u>26</u>	<input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Poured
<input type="checkbox"/> Other, explain: _____ to _____	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

7. **WATER QUALITIES**
Static water level: _____ Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: _____ ° Fahrenheit
Water Quality: _____

PERFORATIONS:

Type of perforation: Factory
Size of perforation: .020

From <u>10.5</u> Feet	To <u>25.5</u> Feet
From _____ Feet	To _____ Feet
From _____ Feet	To _____ Feet
From _____ Feet	To _____ Feet

8. **WELL TEST DATA**

Test Method:	G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
<input type="checkbox"/> Bailor			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision. This report is true to the best of my knowledge.

Name National EWP Contractor
Address 4221 W. Oquendo RD. Las Vegas, NV 89118 Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 0075355
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 2526

Signed: _____
By driller under the actual drilling on site or contractor
Date: 2/9/2016