STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 124666
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37329

1. OWNER PARMAN JOINT LIVING TRUST
MAILING ADDRESS 3571 VERDE AVE
PAHRUMP NV 89048

ADDRESS AT WELL LOCATION 777 W INDOLE ST
PAHRUMP
Subdivision Name: ILVER MOON RANCHETTE *County:* NYE

2. LOCATION NW ¼ NW ¼ Sec 33 T 20S N/S R 53 E
PERMIT/WAIVER No. 35-501-33
Issued by Water Resources Parcel No.

Latitude N36°10'26.7"
Longitude W116°01'40.3"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL		0	5	-5
CLAY		5	118	-113
CLAY & SAND		118	143	-25
CALICHIE		143	155	-12
CLAY		155	167	-12
CALICHIE	WB	167	215	-48
CLAY		215	232	-17
CALICHIE	WB	232	240	-8

Date started: 11-Dec , 20 15
Date completed: 11-Dec , 20 15

9. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9-7/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	240
6	17.02	.250	+2	5

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 180 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 53 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 53 to 240 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. *Water Level*
Static water level: 79 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 65 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING
Contractor
Address 1220 MANSE RD
Contractor
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2513
Signed
By driller performing actual drilling on site or contractor
Date 12/16/2015

(Rev 05-06)
DCNR/DWR/Static
RECEIVED
DEC 23 2015

USE ADDITIONAL SHEETS IF NECESSARY

36.1741219
-116.0272015
NAD 27